

FUNCTIONAL SAFETY CERTIFICATE

CERTIFICATO – ZERTIFIKAT – CERTIFICADO – CERTIFICAT

The products:

PAS – Single Act Scotch-Yoke Pneumatic Actuator
PAD – Double Act Scotch-Yoke Pneumatic Actuator

Manufactured by:

Andishe Gostar Mobin
(Mobin Automation)
NO.110, Vaezi St, Shariati St
Tehran, Iran

suitable for the following safety function(s):

Single Act Actuator: Perform a full stroke by spring thrust effect
Double Act Actuator: Performing a full stroke by the effect of the fluid
working pressure

has been assessed per the relevant requirements of

IEC 61508:2010 Parts 1 to 7

and meets the requirements providing the following:

Systematic Capability:

The compliance with the requirements for the avoidance of systematic faults and the requirements for the control of systematic faults have been achieved following the compliance route 1_S.

SC 2

Hardware Safety Integrity:

The constraints on hardware safety integrity have been verified in order to achieve a sufficiently robust architecture taking into account the level of element and subsystem complexity following the compliance route 1_H.

Type
A

Random Safety Integrity:

The estimated safety integrity, for each safety function, due to random hardware safe and dangerous failures rates (excluding "no part" and "no effect" contribution).

See
page
2

The architectural constraints and the effects of random failures (PFH/PFD_{AVG}) must be verified for each specific application and safety function implemented by the E/E/PE safety-related system.

Certified by:

BYHON

BYHON Certification Director:


Rosati Francesco

CERTIFICATE No:
MOBI-SYPSD-ENS-E01

Revision: A

Issued:
15/11/2021

Valid until:
14/11/2024

The owner of a valid certificate for an assessed product is authorized to affix the following mark and relative ID number, to all recognized devices which are identical to the product assessed.

BYHON
SIL ✓

ID.N° 143221E01N



#8914
ISO/IEC 17065
Product Certification Body